



State of Utah

GARY R. HERBERT  
Governor

SPENCER J. COX  
Lieutenant Governor

Department of  
Environmental Quality

Alan Matheson  
Executive Director

DIVISION OF AIR QUALITY  
Bryce C. Bird  
Director

Document Date: 09/28/2016



DAQ-2016-011514

September 28, 2016

DAQC-1360-16  
Site ID 10238 (B4)

Darrell Cunningham, Plant Managing Director and Responsible Official  
PacifiCorp, Huntington Power Plant  
P.O. Box 680  
Huntington, Utah 84528

Dear Mr. Cunningham:

RE: PacifiCorp, Huntington – Acceptance of Unit 1 as a Mercury Low Emitter Electric (LEE)  
Generating Unit - Title V Permit #1501001004 - 40 CFR §63 Subpart UUUUU Mercury Low  
Emitter EGU Demonstration - Emery County

The Division of Air Quality reviewed Huntington's Unit 1 30-day mercury LEE performance test demonstration conducted on August 11, 2016 through September 13, 2016.

Average mercury emissions were 0.5 lb./year during the 30-day test period meeting the 29.0 lb./year threshold to qualify as a low emitting EGU stipulated in 40 CFR 63.10005(h). Huntington may now discontinue continuous mercury monitoring (CMM) on Unit 1 and conduct 30-day performance test using method 30B at least once every 12 calendar months.

If the LEE status is lost, Huntington shall commence quarterly mercury stack testing and within six months install and certify a CMM. LEE status can be regained if 3 years of testing and CMM data meet LEE criteria.

Should you or your staff have any questions concerning this matter, contact Norman A. Erikson at (801) 536-4063.

Sincerely,

  
Bryce C. Bird  
Director

BCB:NAE:lk

cc: EPA Region VIII, Joseph L. Wilwerding  
Southeast Utah Health Department